



### OPTIONAL STOPPER DETAILS

#### NOTES:

1. LATERAL SIZE TO BE DETERMINED ON THE BASIS OF TOTAL NUMBER OF FIXTURE UNITS DRAINED, BUT IN NO CASE SHALL THE LATERAL DIAMETER BE LESS THAN FOUR INCHES FOR SINGLE OR MULTIPLE FAMILY RESIDENTIAL AND SIX INCHES FOR COMMERCIAL OR INDUSTRIAL LAND USES.
2. LATERAL TO BE INSTALLED TO PROPERTY LINE.
3. IF LATERAL NOT BUILT, PLUG WYE BRANCH WITH STOPPER.
4. IF RISER NOT BUILT, PLUG LATERAL AT PROPERTY LINE.
5. PROPERTY OWNER SHALL BE RESPONSIBLE TO MAINTAIN AND REPAIR SEWER LATERALS UP TO MAIN.
6. BLANKET PROTECTION FOR PIPES SHALL BE PER APWA STD PLAN 225.



CITY OF BREA

## V.C.P. OR P.V.C. TYPICAL LATERAL

APPROVED:

*Rokhaji*  
CITY ENGINEER

DATE: 10-15-2013

STD. PLAN NUMBER

202-0

SHEET 1 OF 1