



**NOTES:**

1. CLEANOUT PIPE TO BE THE SAME SIZE AND KIND OF MATERIAL AS LATERAL.
2. CLEANOUTS TO BE INSTALLED WITHIN 5' OF BUILDING, DIRECTION CHANGES. MAXIMUM 75' INTERVALS AND AT PROPERTY LINE.



**LATERAL CLEANOUT DETAIL**

APPROVED: *R. Raji*  
CITY ENGINEER

DATE: 10-15-2013

STD. PLAN NUMBER  
**203-0**  
SHEET 1 OF 1