



**NOTES:**

1. A 4" WATER SERVICE MANIFOLD MAY BE CONSTRUCTED FOR 3 TO 10 SERVICES TO A TOTAL MAXIMUM DEMAND OF 200 GPM.
2. WATER MAINS AND FITTINGS SHALL BE CONSTRUCTED IN CONFORMANCE WITH BREA STD PLAN 301. VALVES SHALL BE INSTALLED IN CONFORMANCE WITH BREA STD PLAN 302. WATER SERVICES SHALL BE CONSTRUCTED IN CONFORMANCE WITH BREA STD DET 304 OR 305. ALL FITTINGS SHALL BE RESTRAINED IN CONFORMANCE WITH BREA STD PLAN 312.
3. THE UNIT NUMBER SERVED BY EACH METER SHALL BE STAMPED ON THE TOP OF THE CURB ADJACENT TO THE METER BOX LID.



**4" WATER SERVICE MANIFOLD**

APPROVED:

*[Signature]*  
CITY ENGINEER

DATE: 10-15-2013

STD. PLAN NUMBER

**310-0**

SHEET 1 OF 1