

**MEDIAN SECTION WITH BRICK BANDING  
(EXISTING STREET)**

NOTES: SEE SHEET-2



**LANDSCAPE MEDIAN**

APPROVED:


*[Handwritten Signature]*  
CITY ENGINEER

DATE: 10-15-2013

STD. PLAN NUMBER

**118-0**

SHEET 1 OF 4



**MEDIAN SECTION AT NARROW NOSE  
(EXISTING STREET)**

**NOTES:**

- ① LS INSTALL LANDSCAPING AND IRRIGATION IMPROVEMENTS PER PLANS.
- ① SAWCUT AND REMOVE EXISTING ROADWAY STRUCTURAL SECTION AND SOIL TO 30" BELOW EXISTING AC SURFACE. PLACE IMPORTED CLASS A TOP SOIL TO ELEVATION 2-INCHES LOWER THAN TOP OF BACK OF CURB OR ADJACENT BRICK PAVERS.
- ② SANDBLAST CONFLICTING EXISTING MEDIAN STRIPING AND CONSTRUCT PCC CURB W/ DOWEL (8" CF) PER APWA STD PLAN 120.
- ③ INSTALL SAND-SET PAVER EDGE BANDS OR INFILL PER INTERLOCKING PAVER INSTALLATION DETAIL ON SHEET-4.
- ④ INSTALL 30MM THICK PLASTIC MOISTURE BARRIER PER TYPICAL SECTIONS AND MANUFACTURER'S SPECIFICATIONS/ DEPTH OF BARRIER SHALL BE 30" MIN.




**LANDSCAPE MEDIAN**

APPROVED: *[Signature]*  
CITY ENGINEER

DATE: 10-15-2013

STD. PLAN NUMBER  
**118-0**  
SHEET 2 OF 4



**MEDIAN SECTION AT HARDSCAPE AREA  
(EXISTING STREET)**

NOTES: SEE SHEET-2



CITY OF BREA

**LANDSCAPE MEDIAN**

APPROVED:


*Handwritten signature*  
CITY ENGINEER

DATE: 10-15-2013

STD. PLAN NUMBER

118-0

SHEET 3 OF 4



**INTERLOCKING PAVER INSTALLATION**  
**(EXISTING STREET)**

**NOTES:**

- A. INTERLOCKING PAVER. PAVER SIZE: 4" x 8" x 2-3/8" EDGE BAND. SINGLE OR DOUBLE ROW SOLDIER COURSE PATTERN.
- B. 1" THICK BEDDING SAND.
- C. "PAVE EDGE" RIGID SUPPORT BY PAVE TECH, INC., OR APPROVED EQUAL.
- D. "PAVE EDGE" SPIKE. SPACING PER MANUFACTURER'S SPECIFICATIONS.
- E. NON-COMPACTED PLANTING AREA SOIL.
- F. 4-5/8" THICK AGGREGATE BASE PER SPECIFICATIONS. BASE EXTENDS 8" BEYOND EDGE OF PAVERS.
- G. MOISTURE BARRIER. SEAL TO BACK OF CURB (TYP. ON BOTH SIDES).
- H. 8" CURB WITH DOWEL.
- I. INTERLOCKING PAVER. PAVER SIZE: 4" x 8" x 2-3/8" INFILL. STOCK BOND PATTERN.



**LANDSCAPE MEDIAN**

APPROVED: *Helga J. [Signature]*  
 CITY ENGINEER

DATE: 10-15-2013

STD. PLAN NUMBER  
**118-0**  
 SHEET 4 OF 4